



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on April 9, 2009.

EOX, LLC (DBA GO2 INTERNATIONAL)
2625 TOWNSGATE ROAD
SUITE 330
WESTLAKE VILLAGE, CA 91361
877-369-4872

Facility: # 1 USA

Chemical/ Trade Designation	Function	Max Use
Chlorine Dioxide, Liquid ^[1] [CL]		
GO2	Bactericide Disinfection & Oxidation	50 mg/L

[1] Component A and Component B are to be mixed following manufacturer's use instructions to produce a 0.4% chlorine dioxide solution. Certification applies to finished product.

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.